



Addendum No.2

Issued: September 10, 2019

RFP Name: School Bus - LPG Supply

RFP# 2019-TRN-004

Confirm the size of storage tank that will be available.

Our Engineering firm as spec'd a 10,000 gallon tank.

The district is aware that this will not allow for tankers to deliver propane but feels this is the best option given the ultimate usage we anticipate.