



Addendum No.1

Issued: July 12, 2024

RFP Name: Chiller Replacement at Truman High School

RFP# 2024-PUR-019

Below are answers to questions we have received (**Answer in Red below**):

1. Heat Trace coming back with new or using current one?

We require a new heat trace so please include in bid amount.

2. Could I have a copy of the equipment schedule for the chilled water pumps? They're typically the last page of the mechanical portion of the drawings, many times labeled M500.

Please go to on site and see what pumps we have and provide an exact match replacement. We don't have any architectural drawings for them.

3. I am emailing you on behalf of Carrier Corporation to see if we can be considered an approved equal manufacture to provide a bid on the two subject Chiller Replacement Projects.

No, we are requiring Trane for the replacement.

4. Can you provide information on the existing electrical panels (pictures or as builds) serving the existing chillers at Truman Highschool?

This will require a site visit. Please contact us for a site visit.

5. Attached are the individuals that came to the Pre-bid meeting.

INDEPENDENCE SCHOOL DISTRICT 30

Pre-Bid

Project: Chiller Replacement at Truman High School
RFP# 2024-PUR-019

Meeting Date: July 10, 2024, 9:00 a.m.

Facilitator: Greg McGhee

Place/Room: Truman High School

Name	Company	Phone	E-Mail
Brian Jode	Energy Tech	816 787 3500	Brian@energytalk.com
Scott Courtney	" "	" "	Scott@energytechkc.com
John Ryan	Control Service Co.	(816) 600-5800	jryan@controlservice.com
Walker Scherer	" "	816-668-2646	wscherer@controlservice.com
Max Anderson	Trane	913-660-6778	Maxwell.Anderson@trane.com
JP Pauley	Supener Elect	(816) 810-3909	jpauley@supener-elect.com
Adam Langgoss	STANGER	913 709 7247	ALONGOSS@STANGERINC.COM
LARRY BAKO	QUALITY MECH AMERICAN	816-365-0064	Larry@QUALITYPLUMBING.COM
Taylor Woodard	Boiler	816-315-3615	TWoodard@ABMKC.COM
Adam Kutney	BLS	913-229-0435	akutney@bldgcontrols.com
Joe Hill	Lippert	816 602 9158	jhill@lippertmechanical.com