



Addendum No.1

Date Issued: September 20, 2018

RFP Name: Boiler for Three Trails

RFP# 2018-PUR-030

1. Looking through the RFQ for Three Trails Elementary you call for a high efficiency Lochinvar unit at 1.3mmbtu. This was selected based off the old model sitting out there which is a SBN1300. The output on that unit 1.24mmbtu. This unit is no longer in production. You can use a Lochinvar Crest unit which is model FBN1251 that has an output of 1.203mmbtu or model FBN1501 with an output of 1.464mmbtu.

One boiler Lochinvar Crest unit which is model FBN1251 that has an output of 1.203mmbtu

2. Please clarify the bid date?

Thursday September 27th

3. Please clarify Deadline to schedule inspection of property?

September 21, 2018, 3:30 p.m.