



# Addendum No.1

Date Issued: February 19, 2019

RFP Name: Stair Treads for Bridger, Korte and Procter

RFP# 2019-PUR-005

Below is the change to the specifications of the Stair trend:

The stair tread specification has changed to Roppe# 97- Raised circle vantage design. Bridger needs the base changed to 4.5" in lieu of the 6" base.

Question and Answer (in blue below):

Proctor:

1. Please confirm no work at highlighted exterior stair  
**Yes, no work at highlighted exterior stairs.**
2. Please confirm treads/risers & stringers replaced at Gym/Stage stairs (no work shown)  
**Work will be done by ISD.**
3. Please confirm if resilient stringers are to be replaced  
**No, the resilient strings are not to be replaced.**

Bridger:

1. Please confirm Roppe #99 Tread for all stairs is acceptable (no risers)  
**Changing to Roppe# 97 - Raised circle vantage design.**
2. Please confirm the standard Roppe #95/99 - 12" tread and 1-3/4" nosing is acceptable for a 13" substrate and 2-1/4" nosing (currently what is installed)  
**Changing to Roppe# 97 - Raised circle vantage design.**
3. Please confirm no caution grit tape is to be installed in this scope of work  
**Yes, no caution grit tape is to be installed.**
4. Please confirm we are to install a full size tread and remove the VCT necessary at the top landing of two (2) stairs  
**No, we are not replacing VCT on landings.**

5. Please confirm no work at intermediate and 2<sup>nd</sup> floor landings at the VCT to reducer transition at two (2) stairs (currently what is installed)

**Yes, no work at these areas.**



General Questions:

1. Please confirm Roppe #99 tread only with 6" Roppe base as riser is acceptable

**Changing to Roppe# 97 - Raised circle vantage design; Bridger only needs the 4.5" instead of the 6" Riser.**