



## Addendum No. 2

Date Issued: March 26, 2021

RFP Name: Exterior LED Upgrade for District Buildings RFP

RFP# 2021-PUR-005

Below are the questions with answers (in red):

1. Confirming we are including fixture cost in our proposal? Yes / No?  
**Yes**
2. Will there be an addendum issued identifying the descriptive fixture type on the Bid Sheet (page 19) and which fixture in Attachment A it is associated with? This is for all schools. Example: Blackburn Elem. – calls for (6) Large wall packs, is it a wall pack on page 20 (and what wattage) or page 21 (also what lumens). Can you identify a part number in Attachment A to correspond with the fixture type on the Bid Form Matrix?  
**Page # 20 - Large wall packs are 80 W 11360 lumens**  
**Page # 21 - Architectural angle wall pack 5 only at Sycamore Hills 3500 lumens**  
**Page # 25 - Single Head Emergency**  
**Page # 26 - Small doorway pack**  
**Page # 27 - Light pole kit for Sycamore Hills**  
**Page # 28 - Santa Fe Annex canopy lights**  
**Page # 29 - Small canopy 3L, large canopy 7l**  
**Page # 30 - Recessed lights**  
**Page # 31 - Post top for Santa Fe Annex**  
**Page # 32 - Stairway light - Benton Elementary**
3. Sycamore Hills Elementary – The “Area” calls for (1) 20ft pole and 200w fixture, does it go in a new location or replace a pole? If it’s a replacement, which pole is being replaced? If NEW, where is the new location?  
**It's a replacement, and the pole is located on the East side of the building by the receiving area.**

4. What is the prevailing wage order we are to use for labor?

No prevailing wage since project is below \$75,000

5. On fixtures with individual photo eye, are we to provide a new photo eye or use existing?

Use Existing