

# Addendum No. 3



Date Issued: March 18, 2020

RFP Name: Carpet and Cove Base for District Buildings RFP  
RFP# 2020-PUR-005

1. I have a question regarding the LVT for William Southern, are you going to specify one or can we make a suggestion? There isn't that much needed.

*Please suggest.*

2. Also, we discussed the High Shine, 3000 level, for the polished concrete in Nowlin. Are you going to issue another addendum with this information?

*This has been changed to Level 2 Satin and listed below is the description:*

*A level 2 honed polish is obtained by stopping at the 400-grit resin bond, producing a low-sheen finish. When you look directly down at the finished floor and at a distance of roughly 100 feet, you can start to see a slight overhead reflection. This grit level produces a low-luster matte finish.*

3. Also, the bid mentions James Bridger Middle School, but there is no defined scope and I wasn't taken there to measure anything. Can I get some clarification on this?

*There is nothing on cove base and carpet at James Bridger Middle School.*