



Addendum No. 3

Issued: February 8, 2024

RFP Name: Replacement of Interior & Exterior Doors for District Buildings

RFP# 2024-PUR-008

Please add the following to the bid the installation of a pair of doors for the cafeteria at Van Horn see quantity/description and picture on page 2.

Quantity	Description
2	Removal of Existing Doors
2	Furnish and installation of 2 each 20 minute/fire rated door prefinished maple wood doors with narrow lite
6	Furnish and installation of standard weight hinges US26D
1	Furnish and installation of exit device Von Duprin 9927-EO-F 26D
1	Furnish and installation of exit device Von Duprin 9927-L-LBR-F 26D to accept Best Core by Others
2	Furnish and installation of closers parallel arm
2	Furnish and installation of 10x34 kickplates
1	Furnish and installation of smoke gasket
1	Furnish and installation of threshold x 72"

Cafeteria

